



# Maintenance



Servicing your Clean Burn furnace in a timely manner is particularly important to keep your furnace running in peak condition. Just as an automobile requires periodic maintenance such as oil changes, engine tune-ups, etc. your Clean Burn furnace also requires regularly scheduled service.

The service intervals which are required to maintain your furnace.

- 1.Periodic Burner, flame Inspection Monthly
- 2.Servicing the metering pump filter at least once a year
- 3.Cleaning the check valve & screen At least two times a year
- 4.Cleaning the canister filter at least 2 times a year
- 5.Cleaning out ash at around 700 hours as indicated on the burner hour meter
- 6.Burner tune-up at least once every 2-3 years
- 7.Cleaning water/sludge out of tank at least once per year

*\*It is extremely important to clean ash from the furnace on schedule to ensure proper function. Please note: Normal use of your furnace may require ash to be cleaned out twice per year depending on the heating season. Heavy, around the clock usage requires more frequent cleanings. For instance, one month of continual running of the furnace is 720 hours (24 hours x 30 days = 720 hours).*

#### WARNING:

Failure to maintain and/or improper servicing by unqualified personnel could adversely affect the proper, safe operation of your furnace, reduce the service life of your furnace and is likely to void your warranty.

It is highly Recommended to use a Clean Burn trained technician.

**1 (800) 432-3552**